NOTE:
20# WHITE BOND
4.250 X 5.500 SIZE

INSTRUCTIONS
FOR REPLACING ELEMENT

SHUT OFF PUMP.

DRAIN FILTER INTO AN APPROVED SAFETY CONTAINER (IN ABSENCE OF ALL SOURCES OF IGNITION) BY LOOSENING DRAIN PLUG IN BASE OF FILTER WITH 3/16" ALLEN WRENCH. TIGHTEN DRAIN PLUG WHEN FILTER IS EMPTIED.

REMOVE CAP NUT FROM FILTER COVER WHILE HOLDING HEX NUT (15/16") AT BASE OF FILTER.

REMOVE BODY ASSEMBLY FROM FILTER HEAD.

DISPOSE OF USED ELEMENT IN SAME MANNER AS OTHER FLAMMABLE MATERIALS AND REPLACE WITH NEW FILTER ELEMENT.

PUT THIN FILM OF OIL ON NEW COVER GASKET, INSTALL SAME AND REPLACE BODY ASSEMBLY.

TIGHTEN CAP NUT, START PUMP AND FLOW APPROXIMATELY ONE GALLON OF FUEL THROUGH NOZZLE INTO VEHICLE TANK OR INTO APPROVED SAFETY CONTAINER (IN ABSENCE OF ALL SOURCES OF INGITION).

CHECK FOR LEAKS.

14-77065

(A2)

VOL
FIG